



\* The listed water well separation distances from contaminant sources shall be increased by 50% whenever aquifer water enters the water well at less than 50-feet below grade. If a 50% increase cannot be achieved, then the greatest possible increase in separation distance shall be provided with such additional measures as needed to prevent contamination

**FIGURE 1: ABSORPTION SYSTEM SEPARATION REQUIREMENTS**